

- >Anti-magnetic
- >Uni-directional, non-reversible
- >Dry dial counter
- >Vacuum sealed counter
- >Hermetically sealed counter
- >With anti-corrosive epoxy resin treated copper body
- >Clear, tempered glass cover
- >Easy to replace, non-corrosive strainer
- >With threaded tail piece

Specifications

- >Meter size : 1/2" (15mm)
- >Maximum flow (Qmax) : 3 m³/h
- >Nominal flow (Qn) : 1.5 m³/h
- >Transitional flow (Qt) : 120 l/h

- >Minimum flow (Qmin) : 30 l/h
- >Starting flow (Qs) : 16 l/h
- >Minimum reading : 0.0001 m³
- >Maximum reading : 99999 m³
- >Nominal Pressure : 10 bar
- >Headloss at Qmax : <1 bar
- >TcsT Pressure : <10 bar
- >Maximum Temperature : 50°C

Weight and Dimension

- >Length : 259 (Lmm)
- >Width : 165 (L1mm) x 98 (Dmm)
- >Height : 114 (Hmm)
- >Connecting thread: G3/4 (19mm) ISOR228"
- >Weight : 1.8 kg.

Total ABC - Php 975,000.00

(Total Amount in Words): NINE HUNDRED SEVENTY FIVE THOUSAND PESOS ONLY.

Quoted by:

Supplier

Prepared by:

Ireen P. Reyes
BAC Member

Noted by:

AUREA O. ADRADOS
BAC Chairman

Terms & Conditions:

1. As a government agency, BLWD shall deal only with a legitimate suppliers/contractors which issue BIR-registered official receipt;
2. All quoted prices must be inclusive of 5% tax for materials & supplies; 6% for labor and 1% expanded withholding tax

Line Items

Item No.	Product/Service Name	Description	Quantity	UOM	Budget (PHP)
1	Water Service Connection Materials/Fittings	Supply and delivery of Seven Hundred Fifty (750) pieces (15mmØ) 1/2" Brass Water Meter for new service connections and meters for sale.	1	Lump Sum	975,000.00

Other Information

Important Note

- >Provide a copy of product description
- >Water meter must be factory calibrated (provide a valid certificate)
- >Supplier and product must be LWUA Accredited (provide a valid certificate)
- >Provide a copy of MWSI/MWCI/NWRB Certificate if any
- >Product should be in conformity with the international standard ISO 4064 and manufactured by an ISO 9000 and ISO 9001 quality accredited company (provide a valid certificate if any)