

**BALANGA WATER DISTRICT**EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100  
Mobile No. +639-190-870-348

RFQ No.: 2023-005

Date

**REQUEST FOR QUOTATION**

Name of Supplier: \_\_\_\_\_

Address: \_\_\_\_\_

Tel. No.: \_\_\_\_\_

Fax: \_\_\_\_\_

Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:


| Item No. | Unit  | Item Description   | Qty | Unit Cost | Amount |
|----------|-------|--|-----|-----------|--------|
|          | pc(s) | <b>Supply and delivery of Seven Hundred Fifty (750) pieces (15mmØ) 1/2" Brass Water Meter for new service connections and meters for sale.</b> | 750 |           |        |
|          |       | <b>Features</b>  |     |           |        |
|          |       | >Vane wheel  |     |           |        |
|          |       | >Multi-jet   |     |           |        |
|          |       | >Straight reading type   |     |           |        |
|          |       | >Made of selected high quality materials designed for Hot and Cold climate   |     |           |        |
|          |       | >Suitable for High and Low pressure area   |     |           |        |
|          |       | >Anti-magnetic   |     |           |        |
|          |       | >Uni-directional, non-reversible   |     |           |        |
|          |       | >Dry dial counter  |     |           |        |
|          |       | >Vacuum sealed counter   |     |           |        |
|          |       | >Hermetically sealed counter   |     |           |        |
|          |       | >With anti-corrosive epoxy resin treated copper body   |     |           |        |
|          |       | >Clear, tempered glass cover   |     |           |        |
|          |       | >Easy to replace, non-corrosive strainer   |     |           |        |
|          |       | >With threaded tail piece  |     |           |        |
|          |       | <b>Specifications</b>  |     |           |        |
|          |       | >Meter size : 1/2" (15mm)  |     |           |        |
|          |       | >Maximum flow (Qmax) : 3 m3/h  |     |           |        |
|          |       | >Nominal flow (Qn) : 1.5 m3/h  |     |           |        |
|          |       | >Transitional flow (Qt) : 120 l/h  |     |           |        |

(Total Amount in Words)

Quoted by:

\_\_\_\_\_  
Supplier


Requested by:

  
**AUREA O. ADRADOS**  
 BAC Chairman

Terms &amp; Conditions:

- As a government agency, BLWD shall deal only with a legitimate suppliers/contractors which issue BIR-registered official receipt;
- All quoted prices must be inclusive of 5% tax for materials & supplies; 6% for labor and 1% expanded withholding tax.

Noted by:

  
**Engr. Charlito G. Rodriguez**  
 General Manager