



PhilGEPS

Philippine Government Electronic Procurement System

Central Portal for
Philippine Government
Procurement Opportunities

Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 9688531
Procuring Entity BALANGA WATER DISTRICT
Title RFQ - Supply and delivery of 5 pieces uPVC Main Pipe 3" x 6M C-100 w/RR and 343 pieces uPVC Main Pipe 4" x 6M C-100 w/RR for expansion and water supply system at EGSA to Don Pepe Subd., Balanga City,

Area of Delivery

Solicitation Number:	2023-011	Status	Pending
Trade Agreement:	Implementing Rules and Regulations	Associated Components	1
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Bid Supplements	0
Classification:	Goods	Document Request List	0
Category:	Water Service Connection Materials/Fittings	Date Published	25/04/2023
Approved Budget for the Contract:	PHP 987,550.00	Last Updated / Time	24/04/2023 15:48 PM
Delivery Period:	30 Day/s	Closing Date / Time	28/04/2023 10:00 AM
Client Agency:			
Contact Person:	Aurea Adrados BAC Chairperson St. Joseph Street Poblacion Balanga City Bataan Philippines 2100 63-47-2373868 balanga_water@yahoo.com		

Description

BALANGA WATER DISTRICT
EGSA, Four-Lanes, Tuyoy, Balanga City, Bataan 2100
Mobile No. +639-190-870-348
RFQ No.: 2023-011

REQUEST FOR QUOTATION

Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:

Name of Supplier:
Address:
Tel. No.:
Fax:

Item Description:

Supply and delivery of 5 pieces uPVC Main Pipe 3" x 6M C-100 w/RR and 343 pieces uPVC Main Pipe 4" x 6M C-100 w/RR for expansion and water supply system at EGSA to Don Pepe Subd., Balanga City, Bataan.

Technical specifications:

uPVC Main Pipe 3" x 6M Series 10 Class-100 w/ rubber ring

- Nominal outside diameter (OD): 90 (mm)
- Diameter tolerance:

- Outside diameter: + 0.3 (mm)
- Ovality: ± 1.1 (mm)
- 3. Minimum socket depth (E): 107 (mm)
- 4. Socket diameter (D1)
- Minimum: 91.1 (mm)
- Maximum: 91.4 (mm)
- 5. Minimum thickness (t): 4.4 (mm)
- 6. Tolerance: + 0.64 (mm)
- 7. Standard effective length (Le): 6000 (mm)

uPVC Main Pipe 4" x 6M Series 10 Class-100 w/ rubber ring

- 1. Nominal outside diameter (OD): 110 (mm)
- 2. Diameter tolerance:
- Outside diameter: + 0.4 (mm)
- Ovality: ± 1.4 (mm)
- 3. Minimum socket depth (E): 114 (mm)
- 4. Socket diameter (D1)
- Minimum: 111.4 (mm)
- Maximum: 111.8 (mm)
- 5. Minimum thickness (t): 5.3 (mm)
- 6. Tolerance: + 0.73 (mm)
- 7. Standard effective length (Le): 6000 (mm)


TOTAL ABC - Php 987,550.00

(Total Amount in Words): NINE HUNDRED EIGHTY SEVEN THOUSAND FIVE HUNDRED FIFTY PESOS ONLY.


Quoted by:

Supplier

Prepared by:


 Ireen P. Reyes
 BAC Member

Noted by:


 AUREA O. ADRADOS
 BAC Chairman

Terms & Conditions:

1. As a government agency, BLWD shall deal only with a legitimate suppliers/contractors which issue BIR-registered official receipt;
2. All quoted prices must be inclusive of 5% tax for materials & supplies; 6% for labor and 1% expanded withholding tax

Line Items

Item No.	Product/Service Name	Description	Quantity	UOM	Budget (PHP)
1	Water Service Connection Materials/Fittings	Supply and delivery of 5 pieces uPVC Main Pipe 3" x 6M C-100 w/RR and 343 pieces uPVC Main Pipe 4" x 6M C-100 w/RR for expansion and water supply system at EGSA to Don Pepe Subd., Balanga City, Bataan.	1	Lump Sum	987,550.00

Other Information

Important note:

1. Provide a copy of product description and technical specification
2. Provide a copy of test reports of the product
3. Product must be compliant with PNS 65: 1993 (provide a valid certificate)

Created by Aurea Adrados
Date Created 24/04/2023

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.