

**BALANGA WATER DISTRICT**EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100  
Mobile No. +639-190-870-348

RFQ No.: 2023-004

Date

**REQUEST FOR QUOTATION**

Name of Supplier: \_\_\_\_\_

Address: \_\_\_\_\_

Tel. No.: \_\_\_\_\_

Fax: \_\_\_\_\_

Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:


Item No.	Unit	Item Description	Qty	Unit Cost	Amount
	<b>Lumpsum</b>	<b>Supply and delivery of 32 pcs. uPVC Main Pipe 2" x 6M C-100 w/ RR (Bo. Campo Tenejero) and 338 pcs. uPVC Main Pipe 3" x 6M C-100 w/RR (Dangcol) for expansion and rehabilitation of water supply system at Balanga City, Bataan.</b>	<b>1</b>		
		<b>Item specifications:</b>			
	<b>pcs</b>	<b>uPVC Main Pipe 2" x 6M Series 10 Class-100 w/ rubber ring</b>	<b>32</b>		
		1. Nominal outside diameter (OD): 63 (mm)			
		2. Diameter tolerance:			
		Outside diameter: + 0.3 (mm)			
		Ovality: ± 0.8 (mm)			
		3. Minimum socket depth ( E ): 97 (mm)			
		4. Socket diameter (D1)			
		Minimum: 63.8 (mm)			
		Maximum: 64.1 (mm)			
		5. Minimum thickness (t): 3.0 (mm)			
		6. Tolerance: + 0.50 (mm)			
		7. Standard effective length (Le): 6000 (mm)			
	<b>pcs</b>	<b>uPVC Main Pipe 3" x 6M Series 10 Class-100 w/ rubber ring</b>	<b>338</b>		
		1. Nominal outside diameter (OD): 90 (mm)			
		2. Diameter tolerance:			
		Outside diameter: + 0.3 (mm)			
		Ovality: ± 1.1 (mm)			

(Total Amount in Words)

Quoted by:

\_\_\_\_\_  
Supplier


Requested by:

  
**AUREA O. ADRADOS**  
BAC Chairman

Terms &amp; Conditions:

- As a government agency, BLWD shall deal only with a legitimate suppliers/contractors which issue BIR-registered official receipt;
- All quoted prices must be inclusive of 5% tax for materials & supplies; 6% for labor and 1% expanded withholding tax

Noted by:

  
**Engr. Charlito G. Rodriguez**  
General Manager