

BALANGA WATER DISTRICT

EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100 Mobile No. +639-190-870-348

RFQ No.:

2024-002

Date

REQUEST FOR QUOTATION					
Name of Supplier: Address: Tel. No.:			Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:		
Fax:					
Item No.	Unit	Item Description	Qty	Unit Cost	Amount
		Complete and delivery of Buses Cofety Veloc	400		
	pc(s)	Supply and delivery of Brass Safety Valve	480		
		3/4" ø (20mm) for new service connections			
		Specifications:			
		>Brass body with stainless steel lock key			
		>Threaded NPT			
		>Solid Wedge Disc			
		>Nominal pressure: PN 16 (235 psi)			
		>Working Temperature: 20 °C to ≤ 120 °C			
		>Tamper proof valve			
		>Size mm - 20mm			
		>Length (L) mm - 46.0			
		>Height (H) mm - 76.0			
		>Pressure Rating -20 bar			
		Note:Preferably the item/product must have			
		analysis and testing certificate issued by metals			
		industry research and development center			
		(MIRDC)			
/T - 1 - 1 A 1 '	5- 14/I-1				
(Total Amount i	n Words)				
Quoted by: Supplier			Requested by:		
				AURFA O	ADRADOS
			AUREA O. ADRADOS BAC Chairman		
Terms & Conditions:					
			Noted by:		
suppliers/contractors which issue BIR-registered official receipt;			Engr. Charlito G. Rodriguez General Manager		
 All quoted prices must be inclusive of 5% tax for materials & supplies; for labor and 1% expanded withholding tax 					