

**BALANGA WATER DISTRICT**  
**EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100**  
**Mobile No. +639-190-870-348**


**RFQ No.: 2024-013**

**REQUEST FOR QUOTATION**

<b>Name of Supplier:</b>	Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:
<b>Address:</b>	
<b>Tel. No.:</b>	
<b>Fax:</b>	

Item No.	Unit	Item Description	Qty	Unit Cost	Amount
	unit	<b>Supply and delivery of various uPVC Pipes for expansion, rehabilitation, and interconnection of water supply system for various projects of Balanga Water District.</b>	<b>1</b>		
		uPVC Main Pipe 2" x 6M C-100 w/RR	40		
		uPVC Main Pipe 3" x 6M C-100 w/RR	10		
		uPVC Main Pipe 4" x 6M C-100 w/RR	220		

**TOTAL AMOUNT IN WORDS:**

<p>Quoted by:</p> <p style="text-align: center;">_____</p> <p style="text-align: center;">Supplier</p> <p>Terms &amp; Conditions:</p> <ol style="list-style-type: none"> <li>As a government agency, BLWD shall deal only with a legitimate supplier / contractor which issue BIR-registered official receipt;</li> <li>All quoted prices must be inclusive of 5% tax for materials &amp; supplies; 6% for labor and 1% expanded withholding tax</li> </ol>	<p>Requested by:</p> <p style="text-align: center;">  <b>AUREA O. ADRADOS</b>  <b>BAC CHAIRMAN</b></p> <p>Noted by:</p> <p style="text-align: center;"><b>Engr. Charlito G. Rodriguez</b>  <b>General Manager</b></p>
---	--

**Technical specifications:**

**uPVC Main Pipe 2" x 6M Series 10 Class-100 w/ rubber ring**

1. Nominal outside diameter: 63 (mm)
2. Diameter tolerance:
  - Outside diameter: + 0.3 (mm)
  - Ovality:  $\pm 0.8$  (mm)
3. Minimum socket depth: 97 (mm)
4. Socket diameter
  - Minimum: 63.8 (mm)
  - Maximum: 64.1 (mm)
5. Minimum thickness: 3.0 (mm)
6. Maximum thickness: 3.5 (mm)
7. Standard effective length (Le): 6000 (mm)

**uPVC Main Pipe 3" x 6M Series 10 Class-100 w/ rubber ring**

1. Nominal outside diameter: 90 (mm)
2. Diameter tolerance:
  - Outside diameter: + 0.3 (mm)
  - Ovality:  $\pm 1.1$  (mm)
3. Minimum socket depth: 107 (mm)
4. Socket diameter
  - Minimum: 91.1 (mm)
  - Maximum: 91.4 (mm)
5. Minimum thickness: 4.4 (mm)
6. Maximum thickness: 5.04 (mm)
7. Standard effective length (Le): 6000 (mm)

**uPVC Main Pipe 4" x 6M Series 10 Class-100 w/ rubber ring**

1. Nominal outside diameter: 110 (mm)
2. Diameter tolerance:
  - Outside diameter: + 0.4 (mm)
  - Ovality:  $\pm 1.4$  (mm)
3. Minimum socket depth: 114 (mm)
4. Socket diameter
  - Minimum: 111.4 (mm)
  - Maximum: 111.8 (mm)
5. Minimum thickness: 5.3 (mm)
6. Maximum thickness: 6.03 (mm)
6. Standard effective length: 6000 (mm)

**Important note:**

1. Provide a copy of product description and technical specification
2. Provide a copy of test reports of the product
3. Product must be compliant with PNS 65: 1993 (provide a valid certificate)