



BALANGA WATER DISTRICT
EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100
Mobile No. +639-190-870-348



RFQ No.: 2023-025

REQUEST FOR QUOTATION

Name of Supplier:	Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:
Address:	
Tel. No.:	
Fax:	

Item No.	Unit	Item Description	Qty	Unit Cost	Amount
	lumpsum	Supply and delivery of 125 pcs uPVC Main Pipe 2" x 6M C-100 w/ RR and 54 pcs uPVC Main Pipe 3" x 6M C-100 w/ RR for rehabilitation of water supply system at Villa Lina Subdivision Phase 1, Brgy. Tenejero, Balanga City, Bataan.	1		

TOTAL AMOUNT IN WORDS:

<p>Quoted by:</p> <p>_____</p> <p>Supplier</p>	<p>Requested by:</p> <p> AUREA O. ADRADOS BAC CHAIRMAN</p>
<p>Terms & Conditions:</p> <ol style="list-style-type: none">1. As a government agency, BLWD shall deal only with a legitimate suppliers / contractor which issue BIR-registered official receipt;2. All quoted prices must be inclusive of 5% tax for materials & supplies; 6% for labor and 1% expanded withholding tax	<p>Noted by:</p> <p> Engr. Charlito G. Rodriguez General Manager</p>

Item specifications:

uPVC Main Pipe 2" x 6M Series 10 Class-100 w/ rubber ring

1. Nominal outside diameter (OD): 63 (mm)
2. Diameter tolerance:
 - Outside diameter: + 0.3 (mm)
 - Ovality: ± 0.8 (mm)
3. Minimum socket depth (E): 97 (mm)
4. Socket diameter (D1)
 - Minimum: 63.8 (mm)
 - Maximum: 64.1 (mm)
5. Minimum thickness (t): 3.0 (mm)
6. Tolerance: + 0.50 (mm)
7. Standard effective length (Le): 6000 (mm)

uPVC Main Pipe 3" x 6M Series 10 Class-100 w/ rubber ring

1. Nominal outside diameter (OD): 90 (mm)
2. Diameter tolerance:
 - Outside diameter: + 0.3 (mm)
 - Ovality: ± 1.1 (mm)
3. Minimum socket depth (E): 107 (mm)
4. Socket diameter (D1)
 - Minimum: 91.1 (mm)
 - Maximum: 91.4 (mm)
5. Minimum thickness (t): 4.4 (mm)
6. Tolerance: + 0.64 (mm)
7. Standard effective length (Le): 6000 (mm)

Important note:

1. Provide a copy of product description and technical specification
2. Provide a copy of test reports of the product
3. Product must be compliant with PNS 65: 1993 (provide a valid certificate)