



**PhilGEPS**

Philippine Government Electronic Procurement System

Central Portal for  
Philippine Government  
Procurement Opportunities

## Bid Notice Abstract

### Request for Quotation (RFQ)

**Reference Number** 11148812  
**Procuring Entity** BALANGA WATER DISTRICT  
**Title** RFQ - Supply, delivery, installation, testing and commissioning of Data Logger (pressure, flow, and level monitoring) for Balanga Water District  
**Area of Delivery** Bataan

<b>Solicitation Number:</b>	2024-036	<b>Status</b>	<b>Awarded</b>
<b>Trade Agreement:</b>	Implementing Rules and Regulations	<b>Associated Components</b>	1
<b>Procurement Mode:</b>	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	<b>Bid Supplements</b>	0
<b>Classification:</b>	Goods	<b>Document Request List</b>	4
<b>Category:</b>	Information Technology Parts & Accessories & Perip	<b>Date Published</b>	15/08/2024
<b>Approved Budget for the Contract:</b>	PHP 100,000.00	<b>Last Updated / Time</b>	12/09/2024 09:29 AM
<b>Delivery Period:</b>	30 Day/s	<b>Closing Date / Time</b>	20/08/2024 10:00 AM
<b>Client Agency:</b>			
<b>Contact Person:</b>	Aurea Adrados BAC Chairperson EGSA, Tuyo Balanga City Bataan Philippines 2100 63-47-0 Ext.0  balanga_water@yahoo.com		

**Description**

BALANGA WATER DISTRICT  
 EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100  
 Mobile No. +639-190-870-348  
 RFQ No.: 2024-036

**REQUEST FOR QUOTATION**

Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:

Name of Supplier:  
 Address:  
 Tel. No.:  
 Fax:

**Item Description:**

Supply, delivery, installation, testing and commissioning of Data Logger (pressure, flow, and level monitoring) for Balanga Water District.

**Specifications:**

Data Logger (Pressure, Flow, and Level Monitoring) with complete accessories and one (1) year data load plan composed of the following specifications:

- 1P2F, 10BAR, 3G, IP68
- 5 years battery life span (internal battery)
- Accurate and complete secured data communication
- Must be better than +/-0.1% FS precision
- Must be better than +/-0.2% FS drift
- No calibration (Lifetime)
- Non-volatile data storage up to a year
- No to loss data from power interruptions
- Data resolution: 1s to 24 hrs.
- Data sampling interval: ≥1s (1 min default)
- Data logging interval: ≥1s 5 min (24hr default)
- Dial interval: ≥ 5 min (24hr default)
- Temperature voltage: Logged (default =hourly)
- Digital flow input type: Industry standard 2-wire interface plus
- Max pulse frequency: 100Hz
- Minimum pulse width: 5ms
- Physical interfaces configuration port: USB connection to PC, Windows tablet or Android phone and tablet
- Expansion port connection for external power sources 6V-30V, NETWORK Quad-band GSM and Penta-band UMTS, SIM Field replaceable, Automatic configuration, Supports roaming SIMS With Signal Strength & Battery Monitoring with ISO 9001:2015 Sentryx - Water Intelligence Platform


Total ABC - Php 100,000.00

(Total Amount in Words): ONE HUNDRED THOUSAND PESOS ONLY.

Quoted by:

\_\_\_\_\_  
Supplier

Prepared by:

  
Ireen P. Reyes  
BAC Member

Noted by:

\_\_\_\_\_  
AUREA O. ADRADOS  
BAC Chairman

Terms & Conditions:

1. As a government agency, BLWD shall deal only with a legitimate suppliers/contractors which issue BIR-registered official receipt;
2. All quoted prices must be inclusive of 5% tax for materials & supplies; 6% for labor and 1% expanded withholding tax

**Line Items**

Item No.	Product/Service Name	Description	Quantity	UOM	Budget (PHP)
1	Information Technology Parts & Accessories & Perip	Supply and delivery, installation, testing and commissioning of Data Logger (pressure, flow, and level monitoring) for Balanga Water District	1	Unit	100,000.00

**Other Information**

Warranty Conditions:

Warranty must be 12 months or more against factory defects

Important Note:

1. Provide supporting documents of the item/s quoted (manufacturer product description, specification, and shop drawing).

**Created by** Aurea Adrados  
**Date Created** 13/08/2024

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.