



**BALANGA WATER DISTRICT**  
EGSA, Four-Lanes, Tuyo, Balanga City, Bataan 2100  
Mobile No. +639-190-870-348



RFQ No.: 2024-045

**REQUEST FOR QUOTATION**

<b>Name of Supplier:</b>	Please quote us your lowest price of the following articles subject to the terms and conditions contained herein:
<b>Address:</b>	
<b>Tel. No.:</b>	
<b>Fax:</b>	

Item No.	Unit	Item Description	Qty	Unit Cost	Amount
	pc(s)	Supply and delivery of fifty (50) pieces (15mmØ) 1/2" Brass Water Meter for rehabilitation of distribution line at San Jose Public Market.	50		

**TOTAL AMOUNT IN WORDS:**

<p>Quoted by:</p> <p>_____</p> <p>Supplier</p>	<p>Requested by: </p> <p><b><u>LORETO Q. PALAD</u></b> <b>BAC CHAIRMAN</b></p>
<p>Terms &amp; Conditions:</p> <ol style="list-style-type: none"><li>1. As a government agency, BLWD shall deal only with a legitimate suppliers / contractor which issue BIR-registered official receipt;</li><li>2. All quoted prices must be inclusive of 5% tax for materials &amp; supplies; 6% for labor and 1% expanded withholding tax</li></ol>	<p>Noted by: </p> <p><b><u>Engr. Charlito G. Rodriguez</u></b> <b>General Manager</b></p>

**Features:**

- >Vane wheel
- >Multi-jet
- >Straight reading type
- >Made of selected high quality materials designed for Hot and Cold climate
- >Suitable for High and Low pressure area
- >Anti-magnetic
- >Uni-directional, non-reversible
- >Dry dial counter
- >Vacuum sealed counter
- >Hermetically sealed counter
- >With anti-corrosive epoxy resin treated copper body
- >Clear, tempered glass cover
- >Easy to replace, non-corrosive strainer
- >With threaded tail piece

**Specifications:**

- >Meter size : 1/2" (15mm)
- >Maximum flow (Q<sub>max</sub>) : 3 m<sup>3</sup>/h
- >Nominal flow (Q<sub>n</sub>) : 1.5 m<sup>3</sup>/h
- >Transitional flow (Q<sub>t</sub>) : 120 l/h
- >Minimum flow (Q<sub>min</sub>) : 30 l/h
- >Starting flow (Q<sub>s</sub>) : 16 l/h
- >Minimum reading : 0.0001 m<sup>3</sup>
- >Maximum reading : 99999 m<sup>3</sup>
- >Nominal Pressure : 10 bar
- >Headloss at Q<sub>max</sub> : <1 bar
- >Test Pressure : <10 bar
- >Maximum Temperature : 50°C

**Weight and Dimension:**

- >Length : 259 (L<sub>mm</sub>)
- >Width : 165 (L<sub>1mm</sub>) x 98 (D<sub>mm</sub>)
- >Height : 114 (H<sub>mm</sub>)
- >Connecting thread: G3/4 (19mm) ISO R228
- >Weight : 1.8 kg.

**Important Note:**

- >Provide a copy of product description
- >Water meter must be factory calibrated (provide a valid certificate)
- >Provide a copy of MWSI/MWCI/NWRB Certificate if any
- >Product should be in conformity with the international standard ISO 4064 and manufactured by an ISO 9000 and ISO 9001 quality accredited company (provide a valid certificate if any)
- >Water meter must be in the industry for more than 20 years (provide a valid certificate from the manufacturer)